Annual Electric Fan Record Sheet

Six Monthly and annual checks. Isolate and clean housing, remove dust from impellers, reassemble and test. Inspect & clean sensor if fitted. Check overun time and adjust.

Date Scheduled	Date Completed	Signature	Comments *(list all faults & remedial actions)*	Date Remedials completed